

green
town

GreenTown Rockford

November 12 | Embassy Suites Rockford Riverfront

Four Rivers Sanitation Authority & Aqua-Aerobic Systems, Inc.

Research Collaboration for
Green Technology Development &
Economic Growth



AQUA-AEROBIC SYSTEMS, INC.
A Metawater Company




AQUA-AEROBIC SYSTEMS, INC.
A Metawater Company

Four Rivers Sanitation Authority (FRSA)

- A Brief History
- Commitment to Protecting our Environment
- Public/Private Partnership Provides Solutions for Future Needs


Aqua-Aerobic Systems

- Partnership History and Achievements
- AquaPrime[®] Advanced Primary Treatment Technology
- AquaNereda[®] Aerobic Granular Sludge Technology
- FRSA Projects
- The Big Picture



Our mission has not changed since we were incorporated on February 1, 1932

Protect the environment and the health of our citizens through effective and efficient removal and treatment of wastewater.





FRSA IS COMMITTED TO PROTECTING
OUR ENVIRONMENT

FRSA Resource Recovery



Biosolids used in agriculture as fertilizer.



15,000 wet tons produced per year.



600 acres of farmland fertilized annually.

FRSA Resource Recovery



Four Rivers high-strength waste receiving station.

Accepts high-strength food waste from local industries.



Methane gas capable of powering the average residential home for 108 days

FRSA Resource Recovery



Three 1400HP Co-Generation engines.
Capable of three megawatts (mWh) of electrical production.



The engines have the capability of running the entire treatment plant and returning one megawatt (mWh) to the power grid.





Protecting Our Watershed: Pecatonica, Sugar, Rock and Kishwaukee Rivers

FRSA IEPA Permit Requirements

Page 2

NPDES Permit No. IL0027201

Effluent Limitations, Discharges, and Monitoring

FINAL

Discharge Number(s) and Name(s): 001-BTP Outfall002 High River Stage High Influent Flow Effluent Limitation Computed based on a design average flow (DAF) or an MGD (design maximum flow rate) from the effective date of this Permit until the expiration date, the effluent of the above discharge(s) shall be as follows:

Parameter	LOAD LIMITS (Monthly DAF/DMFC)			CONCENTRATED LIMITS (mg/L)	
	Monthly Average	Weekly Average	Daily Maximum	Monthly Average	Weekly Average
Flow (MGD)					
CODCr ^{***}	6572 (13244)	13314 (26588)		20	40
Suspended Solids ^{****}	5340 (10680)	10712 (21424)		25	45
pH	Shall be in the range of 6 to 9 Standard Units.				
Flow Criteria ^{****}	Daily maximum shall not exceed 450 per 100 mg. (May through October)				
Chlorine Residual ^{****}					
Amonipin Nitrogen: As (N)				1.5	3.0
March-May/Sept. Oct.	500(1001)	1260(2520)	130(2602)	1.5	3.0
June-August	500(1001)		531(1061)	1.5	3.0
Nov.-Feb.			131(262)		
Total Phosphorus (as P)	Monitor Only				
Total Nitrogen (as N)	Monitor Only				

* Load limits based on design maximum flow which apply only when flow exceeds design average flow. ** Calculated based on (COCs) testing that is in accordance with 40 CFR 136. *** See Federal Conditions. **** See Federal Conditions. ***** See State and Secondary Standards (SWS) removal requirements. In accordance with 40 CFR 133, the TSS removal efficiency shall not be less than 85 percent. The percent removal need not be reported to the IEPA on DMNs if available, as required otherwise in this Permit. For IEPA Inspection and reports. For measuring cost shall be added to the effluent CODCr concentration to determine the effluent CODCr concentration separation of the removal efficiency versus a measured plant for a given pollution parameter, and values of the raw wastewater influent concentrations in the facility and the 30 day average volume of the effluent.

Page 13

NPDES Permit No. IL0027201

Special Conditions

5. Construction plans and schedules for correction

E. Reporting and Monitoring Requirements:

1. Program for SSO detection and reporting; and
2. Program for leaky and reporting basement back-ups, including general public complaints.

F. Third Party Notice File:

1. Describes how, under various overflow scenarios, the public, as well as other entities, would be notified of overflows within the Permittee's system that may endanger public health, safety or welfare;
2. Identifies overflows within the Permittee's system that would be reported, giving consideration to various types of events including events with potential widespread impacts;
3. Identifies who shall receive the notification;
4. Identifies the specific information that would be reported including actions that will be taken to respond to the overflow;
5. Includes a description of the lines of communication; and
6. Includes the identities and contact information of responsible POTW officials and local, county, and/or state level officials.

For additional information concerning USEPA CDMO guidance and Asset Management please refer to the following web site addresses: http://www.aqua-aerobic.com/systems/asset_management/best_practices.pdf and http://www.aqua-aerobic.com/systems/asset_management/best_practices_asset_management_best_practices.pdf

SPECIAL CONDITION 22

A. Subject to paragraph B below, an effluent limit of 0.5 mg/L Total Phosphorus 12 month rolling geometric mean (calculated monthly) basis (hereinafter "Limit"), shall be met by the Permittee by January 1, 2025, unless the Permittee demonstrates that meeting such Limit is not technologically or economically feasible in one of the following manners:

1. the Limit is not technologically feasible through the use of biological phosphorus removal (BPR) processes at the treatment facility; or
2. the Limit would result in substantial and widespread economic or social impact. Substantial and widespread economic impacts must be demonstrated using applicable USEPA guidance, including but not limited to any of the following documents:
 - a. Interim Economic Guidance for Water Quality Standards, March 1995, EPA-823-R-95-002;
 - b. Combined Sewer Overflows – Guidance for Financial Capability Assessment and Schedule Development, February 1997, EPA-823-R-97-004;
 - c. Financial Capability Assessment Framework for Municipal Clean Water Act Requirements, November 24, 2014; and
 - d. any additional USEPA guidance on affordability issues that revises, supplements or replaces those USEPA guidance documents; or
3. the Limit can only be met by chemical addition for phosphorus removal at the treatment facility in addition to those processes currently contemplated; or
4. the Limit is demonstrated not to be feasible by January 1, 2025, but is feasible within a longer timeline, then the Limit shall be met as soon as feasible and approved by the Agency; or
5. the Limit is demonstrated not to be achievable, then an effluent limit that is achievable by the Permittee (along with associated timeline) will apply instead, except that the effluent limit shall not exceed 0.6 mg/L Total Phosphorus 12 month rolling geometric mean (calculated monthly).

B. The Limit shall be met by the Permittee by January 1, 2020, except in the following circumstances:

1. If the Permittee develops a written plan, preliminary engineering report or facility plan no later than January 1, 2025, to rebuild or replace the secondary treatment process(es) of the treatment facility, the Limit shall be met by December 31, 2025; or
2. If the Permittee decides to construct/operate biological nutrient removal (BNR) process(es) incorporating nitrogen reduction, the Limit shall be met by December 31, 2025; or
3. If the Permittee decides to use chemical addition for phosphorus removal instead of BPR, the Limit and the effluent limit of 1.0 mg/L Total Phosphorus monthly average shall be met by December 31, 2025; or
4. The NARP determines that a limit lower than the Limit is necessary and attainable. The lower limit and timeline identified in the NARP shall apply to the Permittee; or
5. If the Permittee participates in a watershed group that is developing a NARP for an impairment related to phosphorus or a risk of eutrophication, and IEPA determines that the group has the financial and structural capability to develop the NARP by the deadline specified in the NARP provisions below.

NPDES Permit No. IL0027201

Special Conditions

In justification of any exception identified in paragraph A or circumstance B, the justification shall be submitted to the Agency at the time of renewal of the permit. Any justification or demonstration performed by the Permittee in paragraph B must be reviewed and approved by the Agency. The Agency may, at its discretion, require additional information or data for justification of any exception identified in paragraph A or circumstance B. No date deadline modification or effluent limitation modification for any of the above (A) or (B) will be effective until it is included in a modified or renewed permit.

The Permittee shall develop and implement a watershed group that is developing a NARP for an impairment related to phosphorus or a risk of eutrophication, and IEPA determines that the group has the financial and structural capability to develop the NARP by the deadline specified in the NARP provisions below.

The NARP shall include a schedule for the implementation of the phosphorus input reductions and other measures. The NARP shall also include specific timelines applicable to the permittee.

The NARP can include provisions for water quality trading to address the phosphorus related risk of eutrophication characteristics in the watershed. Phosphorus/Nutrient trading cannot result in violations of water quality standards or applicable anti-degradation requirements.

FRSA Facility Plan

MAJOR PROCESS AND INFRASTRUCTURE IMPROVEMENTS



RECOMMENDED COMPONENTS

Component 1 - Primary Filtration

Component 2 - Sidestream Fermentation, Aeration Basin Modifications

Component 3 - Sidestream Fermentation Expansion

Component 4 - Thickening and Nutrient Harvesting

Component 5 - Deammonification

Component 6 - Aerobic Granular Sludge

Component 7 - Tertiary Filtration

Component 8 - Biosolids Drying (not shown)

Component 9 - WAS Hydrolysis

Component 10 - Influent Pumping Improvements

Component 11 - Effluent Diffuser

FRSA Facility Plan

Near Term Components Recommended Over the Next 10 years to meet RRWRD's Drivers and Expected Triggers

NO.	CAPITAL IMPROVEMENT COMPONENT	PROJECTED START	PROJECT SUMMARY	ANTICIPATED PROJECT SCHEDULES AND PROBABLE PROJECT COST	
				IMPLEMENTATION DURATION (DESIGN/BID + CONSTRUCTION)	POTENTIAL COST RANGE
1a	Primary Filtration (Phase I)	2020	Replacement of existing Primary Clarifiers 3-4 with four new packaged Primary Filter units (PF1 and PF2 connected; PF3 and PF4 installed).	30-32 months	\$25.7 to 35.4M
11	Effluent Diffuser	2020	Negotiations with IEPA around diffuser permit requirements with associated river study to support discussions.	9-11 months	\$220 to 330k
6a	Aerobic Granular Sludge (Phase I)	2021	Installation of 10 mgd of Aerobic Granular Sludge (AGS) treatment capacity.	42-44 months	\$27.2 to 45.8M
1b	Primary Filtration (Phase II)	2024	Hydraulic connection of Primary Filters (PF3 and PF4) and solids handling improvements.	14-16 months	\$3.8 to 5.2M
2	Sidestream Fermentation	2024	Modification of existing Aeration Basins and conversion of existing abandoned tankage for RAS fermentation.	30-32 months	\$17.2 to 25.8M
9	WAS Hydrolysis	2024	Digester capacity optimization and acceleration of the RAS fermentation process.	21 - 24 months	\$8.1 to 15.3M
5	Deammonification	2025	Installation of a package system / reactor to remove nitrogen from plant recycle flows.	26-28 months	\$12.4 to 20.8M
7	Tertiary Filtration	2026	Installation of Tertiary Filter units to remove phosphorus from plant effluent. Also includes hydraulic improvements including secondary effluent pumping.	42-44 months	\$32.7 to 53.4M
TOTAL ANTICIPATED PROJECT COST (2020 DOLLARS)					\$127.4 to 202.1M

A PUBLIC/PRIVATE PARTNERSHIP PROVIDES THE SOLUTION

FOUR RIVERS SANITATION AUTHORITY NEEDS:

NUTRIENT REDUCTION

RESOURCE RECOVERY

FLEXIBLE CAPACITY TO ENABLE
GROWTH

AGING INFRASTRUCTURE

AQUA-AEROBIC TECHNOLOGY SOLUTIONS:

ENERGY REDUCTION

ENERGY PRODUCTION

INCREASED CAPACITY

SIMPLE TO OPERATE & MAINTAIN

NPV SAVING



Aqua-Aerobic Systems

- Founded in Rockford Area in 1969
- Water and Wastewater Technology
- 155 Employees
- > 10% of Profits Back to R&D



Partnership History: 2011

FRSA & AASI sign Facilities Agreement for water and wastewater research



Partnership History: 2012



Aqua-Aerobic Systems opens Research & Technology Center at FRSA

Partnership History: 2014



First demonstration of AquaPrime®/AquaStorm™ Filter

Partnership History: 2015



First Aqua MegaDisk® prototype installed at R&T Center

Partnership History: 2016



First full-scale (3 MGD) AquaPrime® Filter demonstration

Partnership History: 2017



AASI breaks ground at FRSA for first AquaNereda® System in North America

Partnership History: 2018



FRSA & AASI joint AGS Workshop at WEFTEC 2018 Conference

Partnership History: 2019

WEFTEC 2019

Seeding, Start-up, and Biological Nutrient Removal Performance of North America's First Full-Scale Aerobic Granular Sludge System

Terence K. Reid, P.E.¹, Larry McFall², Darryl Gravagno³, Manuel de los Santos⁴

^{1,3,4}Aqua-Aerobic Systems, Inc., Loves Park, Illinois

²Rock River Water Reclamation District, Rockford, Illinois

¹Email: treid@aquaaerobic.com

²Email: LMcFall@rrwrddst.il.us

³Email: Darryl.gravagno@aquaaerobic.com

⁴Email: mdelossantos@aquaaerobic.com

ABSTRACT

The first full-scale AquaNereda® aerobic granular sludge (AGS) system was commissioned at the Rock River Water Reclamation District (RRWRD) in Rockford, IL. This 31.5 m³/hour (200,000 gpd) AGS demonstration facility (AGSDF) was part of a private-public partnership between Aqua-Aerobic Systems, Inc. (AASI) and RRWRD to demonstrate the first use of AGS technology at a North American municipal wastewater treatment facility. The AGSDF provides a venue for direct testing and measurement of process and water quality parameters through start-up, seeding, acclimation and stabilized operational phases. AGS was obtained from the 833 m³/hr (5.3 MGD) Garmerwolde Nereda plant in the Netherlands, transported to the AGSDF in September 2017 and stored until construction of the facility was completed in January 2018. Granule inventory increased by 100% within six weeks of start-up resulting in stable performance that met 3 mg/L Total Nitrogen (TN) and < 1 mg/L Total Phosphorus (TP) levels without chemical addition.

KEYWORDS

Aerobic Granular Sludge, Nereda, granule, demonstration, seeding, nitrogen, phosphorus, BNR

INTRODUCTION & BACKGROUND

Granular sludge formation was demonstrated in an upflow anaerobic sludge blanket (UASB) reactor nearly 40 years ago (Lettinga, *et al.*, 1980) and later using an anaerobic sequencing batch reactor (SBR) (Wirtz, Dague 1996). Cultivation of granular sludge under aerobic conditions was first demonstrated in a laboratory scale SBR (Morgentrot, Van Loosdrecht, *et al.*, 1997) using a short hydraulic retention time (HRT) to develop rapidly settling granules whose structural elements were retained after weeks of storage. The robust, dense and fast settling AGS presented an opportunity to realize mainstream biological nutrient removal (BNR) using a high biomass concentration without the energy associated with membrane separation. Full-scale, commercial implementation was, however, limited until reliable mechanisms were developed to



FRSA & AASI joint AquaNereda®
presentation at WEFTEC 2019
Conference

Visitors to FRSA




In a typical year, over 200 people visit FRSA to get a first-hand view of the technologies on site.



FRSA Project


Planning Goals



AquaPrime® Overview




FRSA Project AquaPrime® Technology



FRSA Project

Project Design Phases



AquaNereda® Aerobic Granular Sludge

Settleability Video


A Settling Comparison: Conventional Activated Sludge vs. Aerobic Granular Sludge



AQUA-AEROBIC
SYSTEMS, INC.
A Metawater Company


FRSA Project

AquaNereda® Technology




FRSA Project

Project Design Phase-AquaNereda®



Partnership: Effects & Advantages






**AQUA-AEROBIC
SYSTEMS, INC.**
A Metawater Company



Four Rivers
Sanitation Authority



- Access to full-scale process wastewater
- Testing/validation of new products
- Future commercialization (dom/int'l)
- Possible future grants for studies

- INNOVATION
- NEW TECHNOLOGIES
- GREEN ADVANTAGES
 - Energy
 - Footprint
 - Advanced Treatment

- Learn how to apply new technology
- Technical confidence to meet future permits
- \$\$ invested locally
- Enjoy benefits of research



Partnership: Effects & Advantages

COMMUNITY/WORLD IMPACT

ECONOMIC

- Increased local GDP
- Local labor/jobs
- Visitors

PUBLIC RELATIONS

- Educational resource
- Local partnership
- Best in class effluent

TAXPAYER BENEFITS

- Lower rates
- Sustainably designed and operated



**AQUA-AEROBIC
SYSTEMS, INC.**
A Metawater Company



Four Rivers
Sanitation Authority

PROVIDES

TECHNOLOGY

IDEAS

APPLIED
RESEARCH

FACILITY

IDEAS

PROVIDES

ADVANTAGES

- Access to full-scale process wastewater
- Testing/validation of new products
- Future commercialization (dom/int'l)
- Possible future grants for studies

ADVANTAGES

- Learn how to apply new technology
- Technical confidence to meet future permits
- \$\$ invested locally
- Enjoy benefits of research

- INNOVATION
- NEW TECHNOLOGIES
- GREEN ADVANTAGES
 - Energy
 - Footprint
 - Advanced Treatment

COMMUNITY/WORLD IMPACT

ECONOMIC

- Increased local GDP
- Local labor/jobs
- Visitors

PUBLIC RELATIONS

- Educational resource
- Local partnership
- Best in class effluent

TAXPAYER BENEFITS

- Lower rates
- Sustainably designed and operated

Thank you



AQUA-AEROBIC SYSTEMS, INC.
A Metawater Company

green
town

GreenTown Rockford

November 12 | Embassy Suites Rockford Riverfront